



IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict

TEST REPORT Standard DIN EN 60309-1:2013 TUV SUD Test Report	
Report No.:	028-713182551-000_WALL
Date of issue:	31.03.2021
Project handler:	Matthias Klement
Testing laboratory:	TÜV SÜD Product Service
Address:	Daimlerstraße 40 ; 60314 Frankfurt
Testing location:	as above
Client:	Easee AS
Client number:	5010656586
Address:	Grenseveien 19 4313 Sandnes Rogaland NORWAY
Contact person:	Jonas Helmikstol
Standard:	This TUV SUD test report form is based on the following requirements: DIN EN 60309-1:2013
TRF number and revision:	00
TRF originated by:	TUV SUD Product Service, Mr. Reinhold Hug (<i>product specialist</i>)
Copyright blank test report:	This test report is based on the content of the standard (see above). The test report considered selected clauses of the a.m. standard(s) and experience gained with product testing. It was prepared by TÜV SÜD Product Service. TUV SUD Group takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.
General disclaimer:	This test report may only be quoted in full. Any use for advertising purposes must be granted in writing. This report is the result of a single examination of the object in question and is not generally applicable evaluation of the quality of other products in regular production.
Scheme:	<input type="checkbox"/> TUV Mark <input checked="" type="checkbox"/> without certification
Non-standard test method:	<input type="checkbox"/> GS Mark <input type="checkbox"/> NRTL Mark <input type="checkbox"/> EU-Directive
National deviations:	<input type="checkbox"/> No <input type="checkbox"/> Yes, see details under Summary of testing
Number of pages (<i>Report</i>):	19
Number of pages (<i>Attachments</i>):	-

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
Compiled by:	 SIGN-ID 482195 31.03.2021 Matthias Klement		
	(Printed Name and Signature)		
Approved by:	 SIGN-ID 488744 Reinhold Hug		
	(Printed Name and Signature)		
Test sample:	MUC-481635-1, FFM-552333		
Type of test object:	EV Charging Robot		
Trademark:	Easee		
Model and/or type reference:	EVSE		
Rating(s):	1.4 – 22 kW charging power Advanced load balancing Integrated RCD Type-B RFID / NFC-reader Type 2 socket		
Manufacturer:	Same as client		
Manufacturer number:	5010656586		
Address:	Grenseveien 19 4313 Sandnes Rogaland NORWAY		
Sub-contractors/ tests (clause):	N/A		
Name:	N/A		
Order description:	<input type="checkbox"/> Complete test according to TRF		
	<input checked="" type="checkbox"/> Partial test according to manufacturer's specifications		
	<input type="checkbox"/> Preliminary test		
	<input type="checkbox"/> Spot check		
	<input type="checkbox"/> Others:		
Date of order:	2020-02-11		
Date of receipt of test item:	2020-03-24 Munich, 2020-04-02 Frankfurt		
Date(s) of performance of test:	28.05.2020 – 10.03.2021		
Test item particulars:	EVSE for mode 3 charging (wall charger for electrical vehicles) Easee Charger		

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict

Purpose of the product (Description of intended use):

Charging EV

Characteristic data (not shown on the marking plate):

Charging

Charging power: 1.4 – 22 kW

Charging connector: Type 2

Number of phases: 1, 2 or 3

Voltage: 230V / 400V AC (+ - 10%)

Automatic locking of the charger connector

Built-in energy meter

Easee Home: Up to 3 charging robots on the same cable

Easee Charge: Fully scalable

Safety:

Built-in RCD Type B (30mA AC / 6 mA DC)

RCD device is automatically reset by disconnecting the charging cable

Degree of protection: IP54

Impact resistance: IK10

Fire class: UL94

Insulation class: II

Surge class: III

General

Dimensions: H:256 x W:193 x D:106

Operating temperature: -30°C til 40°C

Weight: 1.5 kg

Attachments:

-

General remarks:

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a **comma** is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict

Summary of testing:

Tested according following clauses of DIN EN 60309-1:2013:

- 9 Protection against electric shock
- 10 Provision for earthing
- 11 Terminals
- 13 Resistance to aging of rubber and thermoplastic material
- 14 General construction
- 15 Construction of socket outlets
- 20 Breaking capacity
- 21 Normal operation
- 22 Temperature rise
- 23 Flexible cables and their connections
- 25 Screws, current-carrying parts and connections
- 26 Creepage distances, clearances and distances through sealing compound
- 27 Resistance to heat, fire and tracking

deviation(s) found

no deviations found

Additional information on Non-standard test method(s)

Sub clause: None

Page: None

Rational:

If additional information is necessary, please provide

The test contains only the assessment of the plug-in connection of the main-connection.



The assessment based on the applicable clauses of the standard.

The actual standard DIN EN 62752 for plug-in connection of an in-cable control and protection device (IC-CPD) does not provide requirements for the terminals for connection to supply mains. Therefore the applicable requirements of DIN EN 60309-1 were tested.

Non-applicable clauses and points are marked with N/A

Copy of marking plate:

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict



IEC 60309-1 & 2

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Picture of the product:**Power supply housing ; Netzanschluss-Gehäuse****Name and address of factory (ies)** (only if certification is provided):

Norautron AS
 Nedre vei 8, Bygg 25
 3183 Horten
 Norway

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict

Possible test case verdicts:			
test case does not apply to the test object:	N/A (not applicable / not included in the order)		
test object does meet the requirement:	P (Pass)		
test object does not meet the requirement:	F (Fail)		
Possible suffixes to the verdicts:			
suffix for detailed information for the client:	C (Comment)		
suffix for important information for factory inspection:	M (Manufacturing)		

9	PROTECTION AGAINST ELECTRIC SHOCK		-
9.1	Live parts not accessible with test finger		P
	Contact between one pin and contact tube impossible		P
	Conformity to Standard sheet: ensure compliance	Special connection System	N/A
9.2	Earthing connection: made before phase and neutral connection	Clamp for PE is leveled above the other clamps	P
	and broken after phase and neutral		P
	Conformity to Standard sheet: ensure compliance .. :	Special connection System	N/A
9.3	Impossible assemble plug contacts into enclosure		N/A

10	PROVISION FOR EARTHING		-
10.1	Earthing contact provided with earthing terminal		P
	External earthing terminals visible from outside	No metal casing and no external earthing terminals	N/A
	Connection reliably		P
	Insulating transformer: not connected to earthing	No insulation transformer in the observed connections	N/A
10.2	Accessible metal parts: reliably connected	Housing without metal parts	N/A
	Resistance not exceed 0.05Ω $I = 25 A$		N/A
10.3	Temperature rise: clause 22		P
10.4	Earthing contact protected against mechanical		P
	Not permitted side earthing contacts		N/A

11	TERMINALS		-
11.1.1	Rewirable accessories accept flexible conductors		P
11.1.2	Non-rewirable accessories provided with soldered, welded or crimped connections	No such connection	N/A
11.1.3	Terminals without special preparation	Connections with screws are terminals for wire end ferrule Other connections are screwless	P

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
11.1.4	Terminals:		-
	- copper		N/A
	- alloy 58 % copper (worked cold) or 50 % other parts	U-Tail-Terminal: CuZn37	P
	- other metal not less resistant to corrosion	Clamps certified according UL486A-B and UL486C	P
	Steel screws protected against corrosion		N/A
11.1.5	Body of earthing terminal: same metal as 11.1.4		P
	Clamping screws or nuts: same metal as 11.1.4		P
	Body or earthing terminal protected against corrosion		N/A
11.1.6	Terminals properly fixed, not work loose when clamping screws are tightened or loosened		P
	Screws and nuts not serve to fix any other components		P
11.1.7	Each terminal located correctly		P
11.1.8	Terminals be located or shielded that:		P
	- screws becoming loose from the terminals, not establish electrical connection between live parts and metal parts connected to the earth		P
	- conductors becoming detached from live terminals not touch metal parts connected to the earth		P
	- conductors becoming detached from the earth not touch live parts		P
11.1.9	The free wire of a conductor connected to live terminals middle size (specified in Table 3): type; cross-sectional area (mm ²) :	Provided wires were used 6mm ²	P
	One wire, length 8 mm of a stranded conductor bent in every direction, no contact with:		P
	- accessible metal parts	No such parts	N/A
	- not emerge for enclosure		P
	The free wire of a conductor connected to the earthing terminal, not touch any live part		P
11.2			-
11.2.1	Terminals allow proper connection of conductors as in Table 3; gauges as in Fig. 13		P
	other terminals shall be used suitable gauge	Tested with conductors	P
	Pillar terminal depth of the hole at least half the diameter of the screw		P
	Lug terminal accept conductor as in Table 3		P
	Screw type identified by the terminal size as in Table 107 comply with S.S. as in 11.101		N/A

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
11.2.2	Terminals: appropriate mechanical strength (§ 25.1)		P
	Thread of screws or nuts ISO or equivalent		P
11.2.3	Conductors clamping between metal surfaces, without damage (test 11.5)		P
11.2.4	Lug terminals: only for $I \geq 63$ A	According user manual maximum current is 32 A. Not used for this device.	P
	Locking means: spring washer or equivalent		N/A
11.2.5	Clamping screws or nuts:		P
	Locked against accidental loosening		P
	Not possible loosen without tool		P
11.3	Screwless type terminals		N/A
11.3.1	Terminals allow proper connection of conductors as in Table 3; gauges as in Fig. 13		N/A
	other terminals shall be used suitable gauge		N/A
11.3.2	Conductors clamping between metal surfaces, without damage (test 11.5 and 11.6)		N/A
11.3.3	Terminals: appropriate mechanical strength cross sect: mm ²)..... :		N/A
11.3.4	The connection or disconnection either by general tool or device integrated;		N/A
	or simple insertion		N/A
	disconnecting other than a pull only		N/A
11.3.5	Opening for tool clearly distinguishable	No tool necessary	N/A
11.3.6	Terminals:		N/A
	- each conductor is clamped individually		N/A
	- the conductors connected or disconnected either at the same time or separately		N/A
	- comply clause 11.5		N/A
11.3.7	Inadequate insertion of the conductor avoided		N/A
11.3.8	The connected conductor remains clamped		N/A
	Deflection test (principle of test apparatus shown in figure 19a):		-
	- test current (A) (Table 4-4) :		N/A
	Smallest cross-sectional area (Table 3) (mm ²) :		N/A
	Force (N) (table 4-1) :		N/A
	- screwless terminal number..... :		N/A
	- starting point (X = deflection original point) :		N/A
	- requirement: $\leq 2,5$ mV		N/A
	Largest cross-sectional area (Table 3) (mm ²)..... :		N/A
	Force (N) (table 10) :		N/A

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
	- screwless terminal number..... :		N/A
	- starting point (X = deflection original point) :		N/A
	- requirement: ≤ 25 mV		N/A
11.4	Insulation piercing terminals (IPT)		-
11.4.1	IPT allow proper connection of conductors as in Table 3 and Table 10		N/A
11.4.2	Conductors clamping between metal surfaces, without damage (test 11.5 and 11.6)		N/A
	or between metal part and insulated part (11.5 and 11.7)		N/A
11.4.3	IPT appropriate mechanical strength		N/A
	Five insertions and disconnections (mm ²)..... :		N/A
	No damage		N/A
11.4.4	The connection or disconnection either by general tool or device integrated;		N/A
	disconnecting other than a pull only		N/A
11.4.5	Opening for tool clearly distinguishable		N/A
11.4.6	IPT:		N/A
	- each conductor is clamped individually		N/A
	- the conductors connected or disconnected either at the same time or separately		N/A
	- Clause 11.5		N/A
11.5	Mechanical tests on terminals		-
11.5.1	Flexion test:		N/A
	Smallest cross-sectional area (mm ²); height H (mm); mass (kg)..... :	Certified according UL486A-B	—
	Largest cross-sectional area (mm ²); height H (mm); mass (kg)..... :	Certified according UL486A-B	—
	during the test: the conductor does not slip out, no break near clamping unit and no damage	Certified according UL486A-B	N/A
11.5.2	Pull test:		N/A-
	- min. cross-sectional area (mm ²); pull (N)..... :	Certified according UL486A-B	—
	- max. cross-sectional area (mm ²); pull (N)..... :	Certified according UL486A-B	—
	- during the test the conductor does not come out	Certified according UL486A-B	N/A
11.6	Voltage drop test for screwless type terminals and IPT		N/A
	Temperature (°C)..... :		N/A
	Smallest cross-sectional area (mm ²)..... :		N/A
	Current (A)..... :		N/A

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
	Voltage drop after 192 cycles:		-
	- requirement: 22,5 mV or 1,5 times 24th cycle value:		N/A
	- solid conductors		N/A
	- stranded conductors		N/A
	- flexible conductors		N/A
	Largest cross-sectional area (mm ²).....		N/A
	C6rrent (A).....		N/A
	Voltage drop after 192 cycles:		-
	- requirement: 22,5 mV or 1,5 times 24th cycle value:		N/A
	- solid conductors		N/A
	- stranded conductors		N/A
	- flexible conductors		N/A
11.7	Tests for IPT transmitting contact pressure via insulating parts		N/A
11.7.1	Same as 11.6 except:		N/A
	- 384 cycles; voltage drop after 48 th and 384 th cycle;		N/A
	- requirement: 22,5 mV or 1,5 times 48 th cycle value :		N/A
11.7.2	Short-time withstand current test		N/A
	- cross-sectional area (mm ²)		N/A
	- test current (A)		N/A
	- duration of the test current (s)		N/A
	Voltage drop after short-time withstand current test:		N/A
	- cross-section of the conductor (mm ²)		N/A
	- test current (A)		N/A
	- voltage drop (mV) after short-time withstand current test not exceeding 1,5 times before test		N/A
	No change, cracks or deformation		N/A
11.101	Screw type terminals identified by terminal sizes		P
11.101.1	Terminals comply with Standard sheet	2-X	P
11.101.2	Terminals with reduced length of thread (cross sect: mm ²)		N/A
	Pull test: during the test, no movement (N).....		N/A
13	RESISTANCE TO AGEING OF RUBBER AND THERMOPLASTIC MATERIAL		-
	Ageing:		-
	70 °C – 10 days (240 h) for rubber	Test für O-Ringe an Kontakten	P
	80 °C – 7 days (168 h) for thermoplastic		P

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
	No cracks, nor sticky or greasy; no damage		P
14	GENERAL CONSTRUCTION		
14.1	Accessible surfaces: no burrs, flashes, sharp edges		P
	Accessories: 63 A- IP 44 or IP66/IP67 and IP 67	According user manual maximum current is 32 A	N/A
	Accessories 125 A: IP66/IP67 and IP 67	According user manual maximum current is 32 A	N/A
14.2	Screws and fixing means: easily accessible		P
	Fixing not serve any other purpose		P
14.3	Position of earthing or neutral contact:		P
	Not possible for the user alter position		N
14.4	Socket-outlets and connectors: ensure IP without plug		N/A
	Plugs or connectors engaged: IP ensured		N/A
14.101	Not possible operate phase inverter unintentionally	No phase inverter in examined part	N/A
	shall incorporate a latching means		N/A
15	CONSTRUCTION OF SOCKET-OUTLETS		-
15.1	Contacts ensure adequate contact pressure (§ 22)	Contact is ensured by locking the charging station into the wall mounted Housing with the socket outlet.	P
	- Contact tubes: self-adjusting		N/A
	- contact tubes other than earth: floating		N/A
	- earth contact tubes: not floating		N/A
	Gauge: (live pins) (Ø: mm; force: N)		N/A
	(earth pin) (Ø: mm; force: N).....		N/A
15.2	Test plug (pins): not remain (Ø: mm; force: N)	The locking system of the enclosures provides high forces which are needed for intended usage.	N/A
15.3	Socket-outlets permit:		-
	- easily introduction into the terminal		P
	- positioning of conductors		P
	- easily fixed of covers or enclosures		P
15.4	Parts providing protection against electric shock:		-
	- securely fixed, no possible remove without tool		P
	- have adequate mechanical strength		P

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
15.5	Cable entries: allow introduction of conduit.....:		P
15.6	Insulating linings: adequate mechanical strength		N/A
15.7	- Socket-outlets: totally enclosed without plug	Socket outlet is enclosed only when the lid is attached.	P
	- means to ensure IP: securely fixed		N/A
	- lid spring: material corrosion resistant	Lid is removable and not attached to the enclosure.	N/A
	IP 44: drain hole \varnothing >5mm or 20 mm ² (mm) :		N/A
15.8	Socket-outlets > 50 V a.c. or 120 V d.c. : provided with earthing contact		P

20	BREAKING CAPACITY		-
	Accessories without interlock only	Without interlock.	P
	Test voltage: 1,1 rated operating voltage (V).....:	253V	P
	Test current: 1,25 rated current (A: power factor).....:	40A	P
	Number of cycles	50	P
	Plugs and appliance inlets: no tested	50	P
	No sustained arcing occurs. No damage	This product is not intended to be used to supply inductive loads e.g. a motor with a coil. Therefore a power factor was not used during the testing.	P

21	NORMAL OPERATION		-
	Rated operating voltage (V).....:	230 V / 400 V a.c.	P
	Rated current (A; power factor)	32A (This product is not intended to be used to supply inductive loads e.g. a motor with a coil. Therefore a power factor was not used during the testing.)	P
	Number of cycles: with load	1000	P
	without load	1000	P
	Accessories with interlock: tested without current		N/A
	No sustained arcing occur		P
	- After test, no damage and electric test (§ 19.3) (V)	See appended Table 21	P
	- Lid spring: same number of cycles of accessories :		N/A
	Plugs and appliance inlets:		-
	Phase inverters are tested without load	No phase inverter in examined part	N/A
	shall be tested in each position for half cycles		N/A

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict

	wires of the cable not be twisted	No wires, pins are directly connected to electronic board	N/A
--	-----------------------------------	---	-----

22	TEMPERATURE RISE		-
	Test current (A; duration h)	1 h	P
	Pilot contact 2 A (duration h)	No Pilot contact	N/A
	- Rewirable (cross sect; mm ²).....	6 mm ²	P
	- Torque (Nm).....	6 Nm	P
	Phase inverter tested in each of the end position	No phase inverter in examined part	N/A
	Temperature rise of terminals: not exceed 50 K.....	See appended Table 22	P

23	FLEXIBLE CABLES AND THEIR CONNECTIONS		-
23.1	- Plugs and connectors: cable anchorage		P
	Cable anchorage: insulating material or lining		P
	- Cable anchorage: cable not touch accessible metal	Not metal parts	N/A
23.2.1	Non-rewirable plugs and connectors:		N/A
	- Cable complying with IEC 60245-4 (Type: IEC 245...).....		N/A
	Nom. cross sect. (mm ²)		N/A
	- earthing core: colour green/yellow		N/A
	- pilot conductor: at least 1,5 mm ² (mm ²)		N/A
23.2.2	Rewirable plugs and connectors:		-
	- clear how the relief from strain is intended	Description in the installation guide.	P
	- no sharp edges to cable		P
	- anchorage or components: properly positioned		P
	- makeshift method: not used		P
	- suitable for different types of cable		P
	Cable inlet with sleeve: insulating material, free	Sealing plug must be fitted before connecting the cable to the backplate of the product. It functions as a Cable inlet.	P
	Bell-mouthed opening: $\varnothing > 1,5$ times \varnothing cable (mm):	No such opening	N/A
	Helical metal springs: not allowed		P
23.3	Pull test:		P
	Type of cable (IEC 60245-4; mm ²)	2,5mm ² ; Due to the rated current of 32A a 2,5mm ² cable is insufficient.	N/A
	Type of cable (IEC 60245-4; mm ²)	6mm ²	P

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
	Clamping couple (Nm)	1,33 Nm	P
	Pull: 100 times; torque: 1 min (N, torque Nm).....	100 N, torque 0,425 Nm	P
	Cable no damage. After test, displacement \leq 2 mm (mm)		P

25	SCREWS, CURRENT –CARRYING PARTS AND CONNECTIONS		-
25.1	- Connection: withstand mechanical stresses		P
	- Screws with $\varnothing < 3,5$ mm: into metal insert	Screws insert into the metal thread of the terminal.	P
	- Thread of insulating material	No such screws	N/A
	- Other screws	No such screws	N/A
	- Assembly screws (\varnothing : mm; torque: Nm)		N/A
	- Cable anchorage (\varnothing : mm; torque: Nm).....	5,0 mm; 2 Nm	P
	- Terminals (\varnothing : mm; torque: Nm).....	7,8 mm; 7,2 Nm	P
25.2	Length of engagement: \geq 3 mm + 1/3 or 8 mm (mm) :	No such screws	N/A
25.3	Contact pressure: not transmitted through insulating		P
25.4	Screws and rivets: locked against loosening		N/A
25.5	Current-carrying parts: - copper; or		N/A
	- alloy with 50 % copper; or		N/A
	- material no less suitable		N/A
25.6	- Contacts subject sliding action: resistant corrosion	No such contacts	N/A
	- springs of contact tubes: resistant to corrosion	No such springs	N/A

26	CREEPAGE DISTANCES, CLEARANCES AND DISTANCES THROUGH SEALING COMPOUND			
26.1	Insulation voltage (V)	400 V		P
	Creepage distances, between live parts:	required (mm)	observed (mm)	-
	1. different polarity	4	14	P
	2. accessible metal parts	-	-	N/A
	- earthing contacts, fixing screws	4	33	P
	- external assembly screws	4	-	N/A
	Clearances, between live parts:			-
	3. different polarity	4	14	P
	4. accessible metal parts not listed under it. 5	-	-	N/A
	- earthing contacts, fixing screws	4	-	N/A
	- external assembly screws	4	-	N/A
	5. metal enclosures, if not lined	-	-	N/A

000_WALL

IEC 60309-1 & 2				
Clause	Requirement + Test	Result - Remark		Verdict
	- surface on which the base is mounted	-	-	N/A
	6. bottom of any conductors recess	-	-	N/A
	Distance through sealing compound, between live parts covered with at least:			N/A
	7. 2,5 mm of sealing compound and surface	-	-	N/A
	8. 2 mm of sealing compound and any conductor :	-	-	N/A
26.2	Sealing compound: not protrude above edge	No sealing compound		N/A
27	RESISTANCE TO HEAT, TO FIRE AND TRACKING			-
27.2	1 h – 100 °C No change impairing further use			P
	Marking still easily legible			P
27.3	Ball pressure test according to IEC 60695-10-2			-
	Diameter of impression shall not exceed 2 mm			—
	- Parts supporting live parts of rewirable accessories (125 °C; mm)	1,1 mm		P
	- other parts (80 °C; mm)			N/A
27.4	Glow wire test according to IEC 60695-2-11			-
	- parts not necessary to retain current-carrying parts and earthing circuit in position, even though they are in contact with them (650°C).....	Enclosure holding the O-Rings of the pins.		P
	No visible flame, or extinguish within 30 s (s)	No ignition		P
	- parts necessary to retain current-carrying parts and earthing circuit in position (850°C).....	1: Enclosure holding the terminals and U-Tail terminals in their position. 2: Terminal lid		P
	No visible flame, or extinguish within 30 s (s)	1: 5 s 2: 10s		P
27.5	Tracking test according to IEC 60112			
		CTI: 175-249 V (E210499 UL746 PLC3)		N/A
	Solution a – 175 V – 50 drops			N/A
	- insulating parts supporting live parts			N/A
	No flashover or breakdown			N/A
29	CONDITIONAL SHORT-CIRCUIT CURRENT WITHSTAND TEST			-
	Min. conditional short-circuit current: 10 kA			P
	New socket-outlet and mating plug:			P
	Minimum prospective short-circuit current: 10 kA			P
	or higher if specified by manufacturer			N/A
	Protective device: “gG” type fuse (Type).....	32_gG		P
	Prospective short-circuit current: > 10 kA (kA).....	10078 A		P

000_WALL

IEC 60309-1 & 2			
Clause	Requirement + Test	Result - Remark	Verdict
	During test: - no risk for operator;		P
	- no damage for adjacent equipment;		P
	- no arcing and no flashover between poles;		P
	- no melting of fault detection fuse		P
	After test: - accessories mechanically operable		P
	- no contact welding preventing normal opening		P
	- dielectric test as § 19.3 (19.2.1 b or 19.2.2 b)		P

Report No.:

Clause	Requirement + Test	result – Remark	Verdict
--------	--------------------	-----------------	---------

21	1.1 TABLE: electric strength after endurance			P
	rated voltage (V)	:	230V/400V	—
item	test voltage applied between:	test voltage (V)	flashover / breakdown (Yes/No)	
a)	all pole and the body (with and/or without plug). :	1500	No	
b)	each pole and all others	1500	No	
c)	any metal enclosure and metal foil	1500	No	
supplementary information:				

22	TABLE: Temperature rise			P
Specimen	Thermocouple Locations	measured temperature rise (K)	allowed temperature rise (K)	
	Power input cable	25,6	50	
	Enclosure rear	21,6	50	
	Enclosure front	8,0	50	
	Terminal N	41,3	50	
	Terminal L1	46,5	50	
	Terminal L2	47,6	50	
	Terminal L3	44,0	50	
	Nut N on circuit board	31,2	50	
	Nut L1 on circuit board	33,8	50	
	Nut L2 on circuit board	35,1	50	
	Nut L3 on circuit board	35,1	50	
Supplementary information: measured connections N L1 L2 L3				

Report No.:

Clause	Requirement + Test	result – Remark	Verdict
--------	--------------------	-----------------	---------

22	TABLE: Temperature rise			P
Specimen	Thermocouple Locations	measured temperature rise (K)	allowed temperature rise (K)	
	Power input cable	21,8	50	
	Enclosure rear	17,4	50	
	Enclosure front	2,8	50	
	Terminal PE	31,8	50	
	Terminal N	34,0	50	
	Terminal L1	35,4	50	
	Terminal L2	31,7	50	
	Nut PE on circuit board	22,4	50	
	Nut N on circuit board	22,6	50	
	Nut L1 on circuit board	24,5	50	
	Nut L2 on circuit board	22,0	50	
Supplementary information: measured connections for PE N L1 L2				

22	TABLE: Temperature rise			P
Specimen	Thermocouple Locations	measured temperature rise (K)	allowed temperature rise (K)	
	Power input cable	24,5	50	
	Enclosure rear	20,1	50	
	Enclosure front	3,1	50	
	Terminal N	31,5	50	
	Terminal L1	34,5	50	
	Terminal L2	35,1	50	
	Terminal L3	32,0	50	
	Nut N on circuit board	21,6	50	
	Nut L1 on circuit board	23,8	50	
	Nut L2 on circuit board	25,3	50	
	Nut L3 on circuit board	22,9	50	
Supplementary information: measured connections for N L1 L2 L3				